

## **PUBLIC NOTICE**

In accordance with Georgia's Water Quality Control Regulation, and the Fort Stewart Sewage Spill Contingency Plan, notification is hereby made to the public of a gray water release, which was reported on April 2, 2012, from a lift station located at Evans Army Airfield on Fort Stewart. This spill was caused by a backed-up lift station and involved the discharge of approximately 7,350 gallons of water from showers and hand basins to a tributary of Jericho River. Fort Stewart repaired the malfunctioned lift station pump and restored flow to the permitted wastewater treatment plant. Additional corrective action taken consisted of covering the involved land surface with agricultural lime for disinfection and sampling to monitor the tributary. Any questions can be directed to the Directorate of Public Works Environmental Branch at (912) 767-2010.